

CERTIFICATE OF COMPLIANCE

Certificate Number 20161121-S1383
Report Reference S1383-20040415
Issue Date 2016-NOVEMBER-21

Issued to: HOCHIKI AMERICA CORP
SUITE 100
7051 VILLAGE DR
BUENA PARK CA 90621

**This is to certify that
representative samples of**

SMOKE-AUTOMATIC FIRE DETECTORS
Fire Alarm Subassembly: Detector sounder bases, Model ASB, ASB-W and FFO-SBASE, for use with manufacturer's Models ACA-V, ACC-V, ALG-V, ALK-V, ALN-V, FFO-SMOKE, ALK-V2, AIE-EA, ATG-EA, ATJ-EA and FFO-HEAT detector heads. Detector sounder base, Model ASB for use with manufacturer's Model ACD-V.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/UL 268, Standard for Safety for Smoke Detectors for Fire Alarm Systems
ANSI/UL 268A, Standard for Safety for Smoke Detectors for Duct Application
ANSI/UL 521, Standard for Safety for Heat Detectors for Fire Protective Signaling Systems
ANSI/UL 2075, Standard for Safety for Gas and Vapor Detectors and Sensors

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

